

December 08, 2016

Michael Nelson
WSWHE Boces
1153 Burgayne Ave
Ste. 2
Fort Edward, NY 12828

RE: Project: WSWHE-CALC
Pace Project No.: 10371698

Dear Michael Nelson:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
CALC 001	10/8/2016 14:19	12/7/2016 18:14	10371698001	Lead	5.9	15	ug/L
CALC 002	10/8/2016 14:17	12/7/2016 18:15	10371698002	Lead	5.1	15	ug/L
CALC 003	10/8/2016 14:16	12/7/2016 18:16	10371698003	Lead	1.3	15	ug/L
CALC 004	10/8/2016 14:09	12/7/2016 18:21	10371698004	Lead	3.4	15	ug/L
CALC 005	10/8/2016 14:08	12/7/2016 18:22	10371698005	Lead	0.62	15	ug/L
CALC 006	10/8/2016 14:11	12/7/2016 18:24	10371698006	Lead	23.4	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

December 08, 2016

Michael Nelson
WSWHE Boces
1153 Burgayne Ave
Ste. 2
Fort Edward, NY 12828

RE: Project: WSWHE-DMB-Bus-Barn
Pace Project No.: 10371697

Dear Michael Nelson:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
DMBB001	10/8/2016 14:24	12/7/2016 20:50	10371697001	Lead	1.2	15	ug/L
DMBB002	10/8/2016 14:26	12/7/2016 20:53	10371697002	Lead	10.5	15	ug/L
DMBB003	10/8/2016 14:29	12/7/2016 21:08	10371697003	Lead	4.1	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

December 08, 2016

Michael Nelson
WSWHE Boces
1153 Burgayne Ave
Ste. 2
Fort Edward, NY 12828

RE: Project: WSWHE South-Horse Care
Pace Project No.: 10371694

Dear Michael Nelson:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
HC001	10/8/2016 14:49	12/7/2016 20:47	10371694001	Lead	0.67	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

December 08, 2016

Michael Nelson
WSWHE Boces
1153 Burgayne Ave
Ste. 2
Fort Edward, NY 12828

RE: Project: WSWHE-Gick Rd.
Pace Project No.: 10371693

Dear Michael Nelson:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
GR01	10/8/2016 15:37	12/7/2016 17:46	10371693001	Lead	1.1	15	ug/L
GR02	10/8/2016 15:38	12/7/2016 17:54	10371693002	Lead	0.38	15	ug/L
GR03	10/8/2016 15:40	12/7/2016 17:55	10371693003	Lead	0.25	15	ug/L
GR04	10/8/2016 15:41	12/7/2016 17:56	10371693004	Lead	0.24	15	ug/L
GR05	10/8/2016 15:41	12/7/2016 17:58	10371693005	Lead	1.6	15	ug/L
GR06	10/8/2016 15:42	12/7/2016 17:59	10371693006	Lead	0.74	15	ug/L
GR07	10/8/2016 15:43	12/7/2016 18:00	10371693007	Lead	0.77	15	ug/L
GR08	10/8/2016 15:44	12/7/2016 18:01	10371693008	Lead	1.5	15	ug/L
GR09	10/8/2016 15:52	12/7/2016 18:05	10371693009	Lead	5.3	15	ug/L
GR10	10/8/2016 15:47	12/7/2016 18:06	10371693010	Lead	0.9	15	ug/L
GR11	10/8/2016 15:47	12/7/2016 18:07	10371693011	Lead	0.57	15	ug/L
GR12	10/8/2016 15:46	12/7/2016 18:10	10371693012	Lead	0.91	15	ug/L
GR13	10/8/2016 15:45	12/7/2016 18:11	10371693013	Lead	0.95	15	ug/L
GR14	10/8/2016 15:54	12/7/2016 18:13	10371693014	Lead	4.1	15	ug/L

NYSDOH Action Level for Lead of 15 ppb